



मिरा भाईदर महानगरपालिका

स्व. इंदिरा गांधी भवन, मुख्य कार्यालय, छत्रपती शिवाजी महाराज मार्ग,
भाईदर (प.), ता.ठाणे-४०११०१ दुरध्वनी क्रं.२८१९२८२८

बांधकाम / विद्युत विभाग

जा.क्र. मनपा/साबां/वि/शा.अ-२/४५०९/२०२५-२६
दि. १६/१०/२०२५

प्रति,
सिस्टीम मॅनेजर
माहिती तंत्रज्ञान विभाग
मिरा भाईदर महानगरपालिका

विषय :- जाहीर सुचना महानगरपालिकेच्या अधिकृत संकेतस्थळावर प्रसिध्द करणेबाबत.

मिरा भाईदर महानगरपालिका क्षेत्रातील डॉ.बाबासाहेब आंबेडकर मार्गालगत असलेल्या विद्यमान अग्नीशमन केंद्र इमारतीच्या जागेत कम्युनिटी सेंटर बांधणे सदर काम करणेसाठी अतिरिक्त बाबींसाठी मंजूरी घ्यावी लागणार आहे. त्यापैकी सोबत जोडलेल्या बाबींसाठी खुल्या बाजारातून दरपत्रक मागविणे कामी सोबत जोडण्यात आलेले दरपत्रक महानगरपालिकेच्या अधिकृत संकेत स्थळावर प्रसिध्द / upload करण्यात यावेत.


(दिपक खांबित)

शहर अभियंता

मिरा भाईदर महानगरपालिका



मिरा भाईदर महानगरपालिका

स्व. इंदिरा गांधी भवन, मुख्य कार्यालय, छत्रपती शिवाजी महाराज मार्ग,
भाईदर (प.), ता.ठाणे-४०११०१ दुरध्वनी क्रं.२८१९२८२८

बांधकाम / विद्युत विभाग




जा.क्र. मनपा/साबां/वि/उ.अ-2/४४०९/२०२५-२६९

दि. १६/१०/२०२५

// जाहिर नोटीस //

मिरा भाईदर महानगरपालिका क्षेत्रातील डॉ.बाबासाहेब आंबेडकर मार्गालगत असलेल्या विद्यमान अग्नीशमन केंद्र इमारतीच्या जागेत कम्युनिटी सेंटर बांधणे सदर काम करणेसाठी अतिरिक्त बाबींसाठी मंजूरी घ्यावी लागणार आहे त्यापैकी खालील बाबींसाठी खुल्या बाजारातून दरपत्रक मागविण्यात येत आहे.

सदर कामाकरिता दि. 25/10/2025 रोजी संध्या 4.00 वाजेपर्यंत मिरा भाईदर महानगरपालिका, मुख्य कार्यालय बांधकाम/ विद्युत विभाग, 4 था मजला येथे स्वारस्य असलेल्या कंत्राटदाराने / एजन्सीने सोबत जोडलेल्या दरपत्रकातील बाबींकरिता दर भरून देण्यात यावेत.


(दिपक खांबित)

शहर अभियंता

मिरा भाईदर महानगरपालिका



MIRA BHAYANDAR MUNICIPAL CORPORATION
Public Work Department
Indira Gandhi Bhavan, Chhatrapati Shivaji Maharaj Marg,
Bhayandar (W) 401101,
Tal. Dist – Thane, Ph. 28192828

// RATE FORM //

Name of Work :- Proposed Construction of Community Center at Fire Bridge bldg at Bhayandar (W) in MBMC area.

Name and address of Contractor :-

B-2 FORM

Sr. No	Discription	Qty	Unit	Rate
1.	Supplying, Erecting and Commissioning of Dieselo generating set with alternator of 320 KVA output continuous rating. 3 Phase, 415 V. 50c/s 0.8pf. A Ca totally enclosed liquid cooled multi-cylinder diesel engine developing suitable BHP at 1500 rpm with 10% overload for 1 hour in 12 hours. along with standard accessories, self excited self regulated. screen protected alternator with static excitation system running at 1500 RPM as per 15 4722-1968 with voltage regulation +/-5%. Both the engine and alternator direct coupled on a common fabricated steel base frame and mounted on anti vibratring pads with standard control panel comprising meters, switchgears. indicators connected with the suitable wires/cables. complete set enclosed in composite Acoustic enclosure as fully assembled integral unit made of 16 SWG CRCA Sheet, sound absorbing material to restrict sound level upto 75 dB at 1.0 m. provided with first filling of oil, diesel etc. and obtaining necessary approval Electrical Inspector from including suitable AMF panel	1.00	NOS	



(Deepak Khambit)

City Engineer

Mira Bhayander Muncipal Corporastion